



15ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

251Y537/08  
Assessment room (14.9m2)  
PFI-C07-0-710

22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

28ø MVAC  
22ø MA4  
22ø OXY

\*\*Waiting (4.3m2)  
PFI-C07-0-700

28ø AGSS  
22ø MVAC  
15ø OXY

28ø AGSS  
28ø MVAC  
22ø MA4  
22ø OXY

2519C022  
\*\*Corridor 22 (137.1m2)  
PFI-C08-0-836

LOC7/AVSU/001  
W/MGAP

LOC7/AVSU/003  
LOC7/AVSU/002

28ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

15ø OXY  
15ø ENT  
15ø MA4  
22ø MVAC  
22ø AGSS

1003Z001  
Waiting (2.2m2)  
PFI-C08-0-838

2509Z001  
Patient hold (6.0m2)  
PFI-C08-0-836

15ø OXY  
15ø MA4  
22ø MVAC  
22ø AGSS

22ø AGSS  
22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

35ø AGSS

28ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

2510Y035  
Clean Utility Prep (7.5m2)  
PFI-C07-0-735

15ø OXY  
15ø ENT  
15ø MA4  
28ø MVAC  
28ø AGSS  
15ø OXY  
15ø ENT  
15ø MA4  
28ø MVAC

1003Z005  
Control Room (8.7m2)  
PFI-C08-0-861

15ø OXY  
15ø MA4  
22ø MVAC  
22ø AGSS

15ø OXY  
15ø MA4  
22ø MVAC  
22ø AGSS

15ø OXY  
22ø MVAC

15ø OXY  
15ø ENT  
15ø MA4  
28ø MVAC  
28ø AGSS  
15ø OXY  
15ø ENT  
15ø MA4  
28ø MVAC

2510Y518/05  
Resuscitation bay 4 (Paeds) (22.3m2)  
PFI-C07-0-734

15ø OXY  
15ø ENT  
15ø MA4  
28ø MVAC  
28ø AGSS  
15ø OXY  
15ø ENT  
15ø MA4  
28ø MVAC

2510Z005  
\*\*Blood Gas Analyser Bay (1.2m2)  
PFI-C07-0-736

LOC7/MGAP/004  
LOC7/MGAP/003

2510Y518/04  
Resuscitation bay 5 (16.9m2)  
PFI-C07-0-727

15ø OXY  
15ø ENT  
15ø MA4  
22ø MVAC  
22ø AGSS

22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY  
22ø AGSS  
22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

2509Z008  
\*\*Mobile X-ray Bay (6.2m2)  
PFI-C08-0-836

15ø OXY  
22ø MVAC

22ø AGSS  
22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

2510Y518/01  
Resuscitation bay 3 (22.4m2)  
PFI-C07-0-733

2510Z003  
Staff Base (2) (7.4m2)  
PFI-C07-0-725

low level wall - 1000mm

2519C003  
Corridor 3 (73.0m2)  
PFI-C07-0-725

22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY  
22ø AGSS  
22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

2509X151  
Patient WC (3.3m2)  
PFI-C08-0-859

22ø MVAC  
15ø OXY

15ø OXY  
15ø ENT  
15ø MA4  
22ø MVAC  
22ø AGSS  
15ø OXY  
15ø ENT  
15ø MA4  
22ø MVAC

2510Y518/02  
Resuscitation bay 1 (Large) (31.4m2)  
PFI-C07-0-732

2510Y518/03  
Resuscitation bay 2 (23.3m2)  
PFI-C07-0-731

22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY  
22ø AGSS  
22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

2514Z003  
Store - Medical Gas Cylinder (4.6m2)  
PFI-C08-0-857

15ø OXY  
15ø OXY

22ø AGSS  
22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

22ø AGSS  
22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

22ø AGSS  
22ø MVAC  
15ø MA4  
15ø ENT  
15ø OXY

2514X095/01  
Relatives Room (14.9m2)  
PFI-C07-0-729

2509Y026  
Accessible WC (5.2m2)  
PFI-C08-0-858

2509Z004  
Trolley/wheelchair bay (4.7m2)  
PFI-C08-0-856

2519C024  
\*\*Corridor 24 (14.5m2)  
PFI-C08-0-856